



Laboratorium Techniki Budowlanej

Sp. z o.o.

41-306 Dąbrowa Górnicza, ul. Łaski 83 ; NIP 625-21-29-966
Jednostka notyfikowana/NB 1827 Jednostka akredytowana AB661
tel/fax (+48) 32 264 079; LTB@LTB.org.pl
KRS 0000447876; REGON 243166560
Wysokość kapitału zakładowego: 66 000 PLN Sąd Rejonowy Katowice-Wschód VIII
Wydział Gospodarczy Krajowego Rejestru Sądowego; Kapitał zakładowy opłacony w całości



AB 661

Initial Type Testing Certificate (ITT)

Pertinent to Standard EN 14351-1+A1

№ 660/B-2015-3


Laboratorium Techniki Budowlanej carried out the examination of the sliding doors described in test report 660/B-2015
manufactured by:

SŁOWIŃSCY Sp.j.

62-400 Słupca, ul. Wspólna 2, Poland

Test specimen

— Locking points



B=3990 H=2500

System: **THERMAX**

Frame	Pinewood
Sash	Pinewood
Sill	SIEGENIA AUBI
Glazing bead	ECO PASS
Rebate seal	Pinewood
Rebate seal	Int. Dev. M3967
Rebate seal	Schlegel HH0134-01
Rebate seal	Schlegel HH0134-02
Glazing seal	Int. Dev. DS7620
ALU cover	Aluron A1066/25
ALU cover	Aluron A7100
Hardware	SIEGENIA AUBI
IGU	6/18/6/18/6

The parameters for other objects should be declare in compliance with the provisions specified in Standard EN 14351-1+A1

The test results relates only to the tested sample and the test conditions.

Characteristic	Conformity assessment Classification Standard	Conformity assessment: Test Standard/test result
4.5 EN 14351-1+A1	EN 12208	EN 1027
Watertightness	Class E750	Not covered Tight to: 750 Pa
4.14 EN 14351-1+A1	EN 12207	EN 1026
Air permeability	Class 4	Air permeability at 100 Pa (Max test pressure 600 Pa) Reference air permeability at 100 Pa: 3m ³ /h m ² or 0,75m ³ /h m 0,25 m ³ /h m ² or 0,16 m ³ /h m
4.2 EN 14351-1+A1	EN 12210	EN 12211
Resistance to wind load	Class C2	Resistance to wind load Test pressure P1 800 Pa Frame deflection Pressure „+” 1/1051 Pressure „-” 1/1072

Quality Manager

Maciej Żyła
Maciej Żyła

Engineering Manager

Bogdan Wójtowicz
mgr Inż. Bogdan Wójtowicz

Dąbrowa Górnicza, dated 26 February 2015 r.

